


Monitoring Based Commissioning and Data Analytics for Energy Efficiency

HESNI 2016 Annual Conference
May 6, 2016





Presentation Agenda

- Hill Group Overview
- MBCx Definition
- Data Acquisition and Access
- Types of Analytics
- Applications of Analytics
- Examples

Andrew Syrios

- Energy Solutions and Commissioning Manager at The Hill Group
- 12 years in Engineering, Mechanical Service, and Construction Industry
- Registered Professional Engineer
- Certified Energy Manager
- Certified Commissioning Process Management Professional
- LEED AP
- Masters of Business Administration – DePaul University
- Bachelor's of Science Mechanical Engineering - University of Iowa

Monitoring Based Commissioning

Use of real-time data analytics, algorithms, diagnostics, and fault detection, to ensure the facility is operating properly and to continually improve operation 24x7



MBCx

Monitoring based commissioning (MBCx) combines building energy system monitoring with standard retro-commissioning (RCx) practices. MBCx is a measurement-based paradigm that affords improved risk-management by identifying problems and opportunities that are missed with periodic commissioning or basic functional testing that does not incorporate energy measurement.


ASHRAE Study

Action	Observed Savings
Installation of Meters	8% to 25% The Hurricane Effect
Commissioning Only	2.5% to 5% Improved Occupant Awareness
Building Tune-Up and User Management	5% to 15% Improved Awareness, Identification of Simple Operational and Maintenance Improvements and Managing Demand Loads for Sustainable Systems, etc.
Ongoing Commissioning	10% to 40% Improved Awareness, Ongoing Identification of Simple Operational and Maintenance Improvements and Commissioning Management Advantages

Table 1: Expected energy savings from utility monitoring.

ASHRAE Journal - April 2011, p 22

Department of Energy Study



• Study by Ernest Orlando Lawrence Berkeley National Laboratory (2010)
• MBCx Benchmarking Analysis of 28 University Buildings in California
• Median Simple Payback = 3.5 Years
• Median Source Energy Savings = 12%

is operating properly and to continually improve op



MBCx

Monitoring based commissioning (MBCx) combines building energy system monitoring with standard retro-commissioning (RCx) practices. MBCx is a measurement-based paradigm that affords improved risk-management by identifying problems and opportunities that are missed with periodic commissioning or basic functional testing that does not incorporate energy measurement.


ASHRAE Study

Action	Observed Savings
Installation of Meters	0% to 2% The Hawthorne Effect
Bill Allocation Only	2.5% to 5% Improved Occupant Awareness
Building Tune-Up And Load Management	5% to 15% Improved Awareness, Identification of Simple Operations and Maintenance Improvements and Managing Demand Loads Per Electric Rate Schedules
Ongoing Commissioning	15% to 45% Improved Awareness, Ongoing Identification of Simple Operations and Maintenance Improvements and Continuing Management Attention

Table 1: Expected energy savings from utility metering.

ASHRAE Journal - April 2011, p 22

Department of Energy Study



- Study by Ernest Orlando Lawrence Berkeley National Laboratory (2012)
- MBCx Benchmarking Analysis of 24 University Buildings in California
- Median Simple Payback = 2.5 Years
- Median Source Energy Savings = 11%

How do you get the data?


ASHRAE Study

Action	Observed Savings
Installation of Meters	0% to 2% The Hawthorne Effect
Bill Allocation Only	2.5% to 5% Improved Occupant Awareness
Building Tune-Up And Load Management	5% to 15% Improved Awareness, Identification of Simple Operations and Maintenance Improvements and Managing Demand Loads Per Electric Rate Schedules
Ongoing Commissioning	15% to 45% Improved Awareness, Ongoing Identification of Simple Operations and Maintenance Improvements and Continuing Management Attention

Table 1: Expected energy savings from utility metering.

ASHRAE Journal - April 2011, p 22

Department of Energy Study




- Study by Ernest Orlando Lawrence Berkley National Laboratory (2012)
- MBCx Benchmarking Analysis of 24 University Buildings in California
- Median Simple Payback = 2.5 Years
- Median Source Energy Savings = 11%

Bill Allocation Only	2.5% to 5% Improved Occupant Awareness
Building Tune-Up And Load Management	5% to 15% Improved Awareness, Identification of Simple Operations and Maintenance Improvements and Managing Demand Loads Per Electric Rate Schedules
Ongoing Commissioning	15% to 45% Improved Awareness, Ongoing Identification of Simple Operations and Maintenance Improvements and Continuing Management Attention



Table 1: Expected energy savings from utility metering.

ASHRAE Journal - April 2011, p 22



- Study by Ernest Orlando Lawrence Berkley National Laboratory (2012)
- MBCx Benchmarking Analysis of 24 University Buildings in California
- Median Simple Payback = 2.5 Years
- Median Source Energy Savings = 11%

How do you get the data?



How do you access the data?




Web Based

Utility Level





Monthly Energy Data





Interval Data



Monthly Energy Data



Interval Data



Sub Meters and Data Loggers



IoT Enabled Devices and Equipment







Overview

Refrigeration

Supplemental Heat

Maintenance

Controls

Cooling

Cooling Capacity

Refrigeration

- Cooling Coil
- Filter Drier
- Sight Glass
- Refrigerant Line Gauge Ports

Setpoints

Operations

Capacity

Refrigeration Live Data

Unit Overview

Tensors Setpoints

Control Temperature:	71.5 °F
Discharge Air Temperature:	55.3 °F
Outside Air Temperature:	80.0 °F
Space Temperature:	71.5 °F
DAT Cooling Lock:	50.0 °F
Return Air Temperature:	74.3 °F
Uncooled Cooling Setpoint:	55.0 °F
Uncooled Heating Setpoint:	55.0 °F
Gas Cooling Setpoint:	72.0 °F
Gas Heating Setpoint:	60.0 °F

Measured Calculated

Operating Hours

Setpoints

Discharge Air Temperature

Cooling Reset

DAT Cooling Setpoint (°F)

DAT Heating Setpoint (°F)

Heating Reset


Network

55.0

60.0


Network

Application Specific




System Level Data Analytics

Typical Architecture




System Level Data Analytics

Front End Data Push




System Level Data Analytics

Direct Backbone Connection with On Site Server



System Level Data Analytics

Direct Backbone Connection with Off Site Server





How do you access the data?

- Web-Based
- VPN, Remote Desk-Top Connection, Team Viewer
- Mobile App



Other Considerations

[illegible]

Monitoring Based Commissioning

Use of real-time data analytics, algorithms, diagnostics, and fault detection, to ensure the facility is operating properly and to continually improve operation 24x7



MBCx

Monitoring based commissioning (MBCx) combines building energy system monitoring with standard retro-commissioning (RCx) practices. MBCx is a measurement-based paradigm that affords improved risk-management by identifying problems and opportunities that are missed with periodic commissioning or basic functional testing that does not incorporate energy measurement.


ASHRAE Study

Action	Observed Savings
Installation of Meters	8% to 25% The Hurricane Effect
Assessment Only	2.5% to 25% Improved Occupant Awareness
Building Tune-Up and User Management	5% to 15% Improved Awareness, Identification of Simple Operational and Maintenance Improvements and Managing Demand Loads for Sustainable Systems, etc.
Ongoing Commissioning	10% to 40% Improved Awareness, Ongoing Identification of Simple Operational and Maintenance Improvements and Commissioning Management Advantages

Table 1: Expected energy savings from utility monitoring.

ASHRAE Journal - April 2011, p 22

Department of Energy Study




• Study by Ernest Orlando Lawrence Berkeley National Laboratory (2010)
• MBCx Benchmarking Analysis of 28 University Buildings in California
• Median Simple Payback = 2.5 Years
• Median Source Energy Savings = 12%

5 Types of Analytics

- **Fault Detection/Diagnostics** – Is it operating as intended?
- **Performance Analysis and Scoring** – How well is it operating?
- **Operational Tuning** – How can I make it operate better?
- **Predictive Maintenance** – Can we identify any issues early?
- **Failure Forensics** – What happened?

VAV / FPB Scorecard



Fault Detection / Diagnostics



Data Analysis

Summary

Device	Records
RTU-1 APLC	256
RTU-2 APLC	256
RTU-3 APLC	256
RTU-4 APLC	256


Device Count: 4; Value Count: 11,264

Drag a column header here to group by that column

Date Time Stamp	1-Duct Static Pressure	1-Duct Static Pressure SP	1-Return Air Temp	1-Return Air Temp Low SP	1-Supply Air Temp	1-Supply Air Temp SP	1-Supply Air Temp (Score)	(Ovr Score)
1/5/2015 6:13:00 AM	2.9	1.2	72.7	37	67.9	68	98	98
1/5/2015 6:28:00 AM	2.9	1.2	72.8	37	67.3	68	86	86
1/5/2015 6:43:00 AM	2.9	1.2	72.8	37	67.6	68	92	92
1/5/2015 6:58:00 AM	2.9	1.2	72.8	37	67.7	68	94	94
1/5/2015 7:13:00 AM	2.7	1.2	72.8	37	66.5	68	70	70




Critical Zone Analysis



Chiller Performance and Predictive Maintenance



Chiller Trend and Efficiency Analysis




Comments: Higher than target kW/ton due to large fluctuations in entering condenser water temperature.

Logs and Scheduled Auto Reports to Engineers

	A	G	H	I	J	K	L	M	N	O	P	Q	F
1	DateTimeStamp	kWTon	Entering CDW Temp	Leaving CDW Temp	Condenser Pressure	Condenser Sat Temp	Evaporator Pressure	Evaporator Sat Temp	Discharge Temp	Oil Pressure	Oil Temp	Motor Current	Phase A Motor C
143	10/27/15 12:27 PM	0.65	76.5	74.0	15.5	82.7	7.4	41.7	116.6	32.5	136.4	49.0	
144	10/27/15 12:32 PM	0.65	66.2	74.0	14.2	74.9	7.4	41.7	116.6	31.3	136.4	49.0	
145	10/27/15 12:37 PM	0.63	66.2	74.0	14.2	74.9	7.4	41.7	116.6	31.3	136.4	49.0	
146	10/27/15 12:42 PM	0.62	70.6	80.7	16.4	74.9	7.4	42.9	120.1	31.3	136.1	51.0	
147	10/27/15 12:47 PM	0.62	70.6	80.7	16.4	72.4	7.3	42.9	120.1	30.5	136.1	51.0	
148	10/27/15 12:52 PM	0.61	70.6	76.7	14.7	72.4	7.3	41.7	116.9	30.5	136.1	49.0	
149	10/27/15 12:57 PM	0.61	73.8	76.7	14.7	72.4	7.3	41.7	116.9	30.5	136.0	49.0	
150	10/27/15 01:02 PM	0.61	73.8	76.7	14.7	76.6	7.4	41.7	116.9	32.1	136.0	49.0	
151	10/27/15 01:07 PM	0.60	73.8	72.4	14.1	76.6	7.4	41.7	116.9	32.1	135.7	49.0	
152	10/27/15 01:12 PM	0.60	67.9	72.4	14.1	76.6	7.4	41.7	115.5	32.1	135.7	49.0	
153	10/27/15 01:17 PM	0.62	67.9	72.4	15.7	76.6	7.4	41.7	115.5	31.5	135.7	49.0	
154	10/27/15 01:22 PM	0.65	68.0	72.0	15.7	77.3	7.4	42.3	117.8	31.5	135.9	50.0	
155	10/27/15 01:27 PM	0.65	68.0	72.0	15.7	77.3	7.3	42.3	117.8	31.5	135.9	50.0	
156	10/27/15 01:32 PM	0.65	68.0	72.0	16.1	77.3	7.3	42.3	117.8	32.1	135.9	50.0	
157	10/27/15 01:37 PM	0.62	70.1	72.0	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
158	10/27/15 01:42 PM	0.64	70.1	74.5	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
159	10/27/15 01:47 PM	0.63	70.1	74.5	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
160	10/27/15 01:52 PM	0.64	72.6	78.8	16.0	79.3	7.3	41.7	117.8	32.1	136.0	50.0	
161	10/27/15 01:57 PM	0.64	72.6	78.8	16.0	79.3	7.3	41.7	117.8	31.2	136.0	50.0	
162	10/27/15 02:02 PM	0.62	72.6	78.8	16.0	79.3	7.3	41.7	115.7	31.2	136.0	49.0	
163	10/27/15 02:07 PM	0.62	72.0	74.7	15.1	77.9	7.3	42.3	115.7	31.2	135.6	49.0	
164	10/27/15 02:12 PM	0.62	72.0	74.7	15.1	77.9	7.3	42.3	115.7	32.3	135.6	49.0	
165	10/27/15 02:17 PM	0.64	72.0	74.7	14.1	77.9	7.2	42.3	117.0	32.3	135.6	49.0	
166	10/27/15 02:22 PM	0.60	69.4	72.0	14.1	72.8	7.2	41.1	117.0	31.3	135.6	49.0	
167	10/27/15 02:27 PM	0.60	69.4	72.0	14.1	72.8	7.2	41.1	117.0	31.3	135.6	50.0	
168	10/27/15 02:32 PM	0.59	69.4	72.0	14.1	72.8	7.2	41.1	118.6	32.1	135.6	50.0	
169	10/27/15 02:37 PM	0.61	65.3	74.8	14.2	72.8	7.3	41.7	118.6	32.1	135.6	50.0	
170	10/27/15 02:42 PM	0.60	65.3	74.8	14.2	72.8	7.3	41.7	118.6	32.1	135.7	49.0	
332	MIN=	0.58	65.3	72.0	14.1	72.4	7.2	41.1	115.5	30.5	135.3	48.0	
333	MAX=	0.73	78.2	83.7	17.5	84.3	7.6	43.5	121.1	33.2	136.9	51.0	
334	AVG=	0.64	71.1	77.4	15.7	78.2	7.4	42.2	118.4	31.9	136.1	49.5	


Event Notifications - AHU Enabled when scheduled off

The screenshot shows an email client interface. At the top, there are tabs for 'FILE', 'MESSAGE', 'ESET', 'ADOBE PDF', and 'PDF-XChange 2012'. The 'MESSAGE' tab is active. Below the tabs, there is a placeholder for a profile picture and the date 'Sun 2/7/2016 11:25 AM'. The email header shows 'To: Andrew Syrios; Peter Nustra'. Below the header, there is a blue information icon followed by the text 'We removed extra line breaks from this message.' A horizontal line separates the header from the message body. The message body starts with a yellow envelope icon and the word 'Message', followed by a green Excel icon and the filename '23rd Floor SF Fan Enable 020716 112358.xlsx (4 MB)'. The main text of the email reads: 'See the attached report', 'Event Notification: 23rd Floor SF Fan Enable', 'Site:', 'Device: MP581-23-1 S1 S2', 'State: Active', and 'Expression: [S1 Fan Enable] <1'. At the bottom, it says 'S1 Fan Enable: 0'.



Demand Reduction and Load Shedding


Morning Demand Reduction



Morning peak demand reduction from 892 kW to 730kW.
Resulting savings of \$907 for 1 month (\$10,886 annual potential)




MBCx through the Life of your Building





Functional Testing

- Document and record functional testing with data and analytics.
- Utilize software as a tool to address issues quickly and ensure quality.
- Cost effectively test 100% of all devices without sampling restrictions






Device	Space Temp deg	Setpoint deg	Current Airflow CFM/PS	Discharge Temp
FFB-34	73	74	230.90706	79
FFB-4	74	74	282.21973	73
FFB 1 Dock/Stockroom	74	75	261.79938	89
FFB 10	72	72	234.57225	70
FFB 11	73	74	117.28613	83
FFB 12	74	74	295.5162	70
FFB 13	75	75	628.58032	75
FFB 15 Multipurpose Rm 201	73	72	345.3606	75
FFB 16 Multipurpose Rm 201	72	72	157.07964	75
FFB 17 Interview Rm 215	70	72	274.88934	87
FFB 18 Human Resources Rm 228	71	71	436.15778	76
FFB 19 Tenant Space Rm 236	73	74	359.18875	83
FFB 20 Tenant Space Rm 236	72	72	196.34955	75
FFB 21 Conference Rm 245	73	73	150.79645	75
FFB 22 Office Rm 246	73	74	159.17403	82
FFB 23 Office Rm 250	71	72	259.70499	81
FFB 24 Tenant Space Rm 252	75	75	166.7662	81
FFB 25 Tenant Space Rm 253	73	72	423.32962	77
FFB 26 Tenant Space Rm 253	74	75	384.84509	86
FFB 27	73	74	243.73523	80
FFB 28	73	73	142.41887	84
FFB 28 Office 301	80	72	301.5828	68
FFB 29	72	72	82.4668	76
FFB 29 Office 320	72	72	108.90855	71
FFB 3 West Perimeter Corridor	73	72	384.84509	71
FFB 30 Office 320	73	74	256.56339	81
FFB 31 Office 320	73	74	192.42255	72
FFB 32 Office 320	76	74	1390.67834	68
FFB 33 Office 305	73	72	381.1799	68
FFB 35 Office 321	72	72	295.04791	72
FFB 36 Office 318	76	74	394.83023	67



Warranty Management and 1st Year Cx


- Ensure the facility operates per the OPR and specifications at all times.
- Assist in operator training.
- Identify, Investigate and, Address issues during the 1st year of operation under warranty.
- Document changes and overrides.




Measurement & Verification

- Measurement and Verification
- How does the facility perform vs. the energy model and performance goals.
- Identify the differences and why.
- Identify opportunities for improvement and make adjustments.
- Qualifies for LEED credits.

TYPE OF SOURCE	TOTALS (ACTUAL)	TOTALS (BASELINE)	TOTALS (PROPOSED)
SPARE	233,801	0	0
COOLING	3,516,735	2,229,436	1,602,073
FANS	2,320,235	1,559,521	2,437,293
HEATING(ELEC)	422,267	0	344,672
INDOOR LIGHTING	1,611,290	989,263	703,225
OUTDOOR LIGHTING	333,640	1,070,680	604,523
PROCESS	5,378,713	3,888,813	3,888,813
PUMPS	11,742	34,249	19,144
RECEPTACLE	212,735	508,166	508,166
DOMESTIC HOT WATER	13,011	51,578	50,910
Total Annual Electric Usage (kWh)	14,054,171	10,331,706	10,158,819
DOMESTIC HOT WATER		51578	50910
KITCHEN EQUIPMENT (GAS)	156000		0
HEATING(GAS)	104831	306648	114518
Total Annual Gas Usage (Therms)	260831	358226	165428






Energy Efficiency

- 10-15% typical energy reduction.
- Utility funded programs and incentives available.
- Focus on corrective and improvement measures.
- Low cost/no cost measures with < 18 Month SPB.

Downtown High-Rise


- 80 Energy Star Prior to MBCx
- Enrolled in the ComEd MBCx Program
- Integrated in the June 2015.
Integration incentive of \$25,000.
- Identified 1,394,316 kWh in energy savings from improper night operation, duct static reset, and modifications to chiller staging. Implementation incentive of \$97,602.
- Zero Cost to Owner through ComEd MBCx Program



Predictive Maintenance


- Evaluate equipment performance and condition 24x7.
- Plan and prioritize maintenance.
- Identify and address issues before they become costly failures.

	A	G	H	I	J	K	L	M	N	O	P	Q	R
1	Date/Time Stamp	NW Ton	Entering CDW Temp	Leaving CDW Temp	Condenser Pressure	Condenser Sat Temp	Evaporator Pressure	Evaporator Sat Temp	Discharge Temp	Oil Pressure	Oil Temp	Motor Current	Motor C
143	10/27/15 12:27 PM	0.65	76.5	74.0	15.5	82.7	7.4	41.7	116.6	32.5	136.4	49.0	
144	10/27/15 12:32 PM	0.65	86.2	74.0	14.2	74.9	7.4	41.7	116.6	31.3	136.4	49.0	
145	10/27/15 12:37 PM	0.63	66.2	74.0	14.2	74.9	7.4	41.7	116.6	31.3	136.4	49.0	
146	10/27/15 12:42 PM	0.62	70.6	80.7	16.4	74.9	7.4	42.9	120.1	31.3	136.1	51.0	
147	10/27/15 12:47 PM	0.62	70.6	80.7	16.4	72.4	7.3	42.9	120.1	30.5	136.1	51.0	
148	10/27/15 12:52 PM	0.61	70.6	76.7	14.7	72.4	7.3	41.7	116.9	30.5	136.1	49.0	
149	10/27/15 12:57 PM	0.61	73.8	75.7	14.7	72.4	7.3	41.7	116.9	30.5	136.0	49.0	
150	10/27/15 01:02 PM	0.61	73.8	76.7	14.7	76.6	7.4	41.7	116.9	32.1	136.0	49.0	
151	10/27/15 01:07 PM	0.60	73.8	72.4	14.1	76.6	7.4	41.7	116.9	32.1	135.7	49.0	
152	10/27/15 01:12 PM	0.60	67.9	72.4	14.1	76.6	7.4	41.7	115.5	32.1	135.7	49.0	
153	10/27/15 01:17 PM	0.62	67.9	72.4	15.7	76.6	7.4	41.7	115.5	31.5	135.7	49.0	
154	10/27/15 01:22 PM	0.65	88.0	72.0	15.7	77.3	7.4	42.3	117.8	31.5	135.9	50.0	
155	10/27/15 01:27 PM	0.65	68.0	72.0	15.7	77.3	7.3	42.3	117.8	31.5	135.9	50.0	
156	10/27/15 01:32 PM	0.65	68.0	72.0	16.1	77.3	7.3	42.3	117.8	32.1	135.9	50.0	
157	10/27/15 01:37 PM	0.62	70.1	72.0	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
158	10/27/15 01:42 PM	0.64	70.1	74.5	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
159	10/27/15 01:47 PM	0.63	70.1	74.5	16.1	77.3	7.3	41.7	118.6	32.1	136.0	50.0	
160	10/27/15 01:52 PM	0.64	72.6	78.8	16.0	79.3	7.3	41.7	117.8	31.2	136.0	50.0	
161	10/27/15 01:57 PM	0.64	72.6	78.8	16.0	79.3	7.3	41.7	117.8	31.2	136.0	50.0	
162	10/27/15 02:02 PM	0.62	72.6	78.8	16.0	79.3	7.3	41.7	115.7	31.2	136.0	49.0	
163	10/27/15 02:07 PM	0.62	72.0	74.7	15.1	77.9	7.3	42.3	115.7	31.2	135.6	49.0	
164	10/27/15 02:12 PM	0.62	72.0	74.7	15.1	77.9	7.3	42.3	115.7	32.3	135.6	49.0	
165	10/27/15 02:17 PM	0.64	72.0	74.7	14.1	77.9	7.2	42.3	117.0	32.3	135.6	49.0	
166	10/27/15 02:22 PM	0.60	69.4	72.0	14.1	72.8	7.2	41.1	117.0	31.8	135.6	49.0	
167	10/27/15 02:27 PM	0.60	69.4	72.0	14.1	72.8	7.2	41.1	117.0	31.8	135.6	50.0	
168	10/27/15 02:32 PM	0.59	69.4	72.0	14.1	72.8	7.2	41.1	118.6	32.1	135.6	50.0	
169	10/27/15 02:37 PM	0.61	65.3	74.8	14.2	72.8	7.3	41.7	118.6	32.1	135.6	50.0	
170	10/27/15 02:42 PM	0.60	65.3	74.8	14.2	72.8	7.3	41.7	118.6	32.1	135.7	49.0	
171	Mean	0.58	65.3	72.0	14.1	72.4	7.2	41.1	115.5	30.5	135.3	48.0	
172	Max	0.73	78.2	83.7	17.5	84.3	7.6	42.5	121.1	33.2	136.9	51.0	
173	AVG	0.64	71.3	77.4	15.7	78.2	7.4	42.0	118.4	31.9	136.1	49.5	





MBCx through the Life of your Building




Utility Funded Programs in Illinois

ComEd MBCx Overview for Existing Buildings

- Eligible buildings > 400,000 SF
- Annual Usage > 8,000,000 kWh; Peak demand > 500 kW
- 18 month "monitoring" period (Contract)
- Low-cost/no-cost energy-savings corrective and improvement measures are identified and fine-tuned
- \$25,000 incentive for software integration and set-up
- \$0.07 per kWh incentive for verified energy savings resulting from the "monitoring" period

ComEd MBCx Process



Ameren- Metering and Monitoring Program

- Base incentive of up to \$10,000 once the new monitoring equipment or software is installed.
- Capped at 50% of cost
- Performance incentive of up to \$10,000 paid based on annual energy savings from implemented projects.
- Incentive paid at \$0.01 per kWh and \$0.20 per therm
- 12 Month monitoring period


UTILITY CHARGES (continued)

Description	Quantity	Unit of Measure	Unit Price	Total Price
Environmental Cost Recovery Adj	478,869	kWh	x 0.000200	95.77
Energy Efficiency Programs	478,869	kWh	x 0.000940	450.14
Franchise Cost	6,780.44		x 0.036470	247.63
State Tax	1.00		x 1436.460000	1436.46
Municipal Tax	1.00		x 1602.130000	1602.13
Subtotal Utility Charges				\$10,666.20
Total Current Charges				\$34,979.51

ComEd MBCx Overview for Existing Buildings

- Eligible buildings > 400,000 SF
- Annual Usage > 8,000,000 kWh; Peak demand > 500 kW
- 18 month “monitoring” period (Contract)
- Low-cost/no-cost energy-savings corrective and improvement measures are identified and fine-tuned
- \$25,000 incentive for software integration and set-up
- \$0.07 per kWh incentive for verified energy savings resulting from the “monitoring” period

ComEd MBCx Process



Ameren- Metering and Monitoring Program

- Base incentive of up to \$10,000 once the new monitoring equipment or software is installed.
 - Capped at 50% of cost
- Performance incentive of up to \$10,000 paid based on annual energy savings from implemented projects.
 - Incentive paid at \$0.01 per kWh and \$0.20 per therm
- 12 Month monitoring period

Example Projects

Corrective Measures

Correct Scheduling of Kitchen Make-up Air and Exhaust System

Example:

- Kitchen make-up air unit and exhaust fans were running 24x7.
- Equipment was scheduled from the front end
- Annual kWh Savings: 296,067 kWh
- Annual Therm Savings: 18,321 Therms
- Annual Cost Savings: \$31,998
- Measure Cost: \$0
- Simple Payback: Instant

Night Set-Back On VAV and FPBs Not Active

Example:

- Approx. 1,000,000 SF Facility
- All zones had night setbacks programmed at the front end, however none of the zones were actively controlling to night setbacks.
- Annual kWh Savings: 708,985 kWh
- Annual Cost Savings: \$46,084
- Measure Cost: \$5,563
- Simple Payback: 0.12 Years

Improper VAV Box Airflow

Example:

- Approx. 1,000,000 SF Facility
- Analytics showed that:
 - Some boxes had improperly set airflow minimums (too high)
 - Some boxes provided too much airflow at maximum
 - Some boxes did not show a change of airflow regardless of damper position (command)
- Annual kWh Savings: 96,425 kWh
- Annual Cost Savings: \$7,714
- Measure Cost: In House Corrections

Enthalpy Sensor Calibration and Rebalancing of OA Dampers

Example:

- Approx. 500,000 SF Facility
- Existing enthalpy sensors were out of calibration
- OA damper minimum position was bringing in more OA than required
- Enthalpy sensors were replaced and OA damper minimum position was rebalanced.
- Annual kWh Savings: 166,866 kWh
- Annual Cost Savings: \$12,132
- Measure Cost: \$11,950
- Simple Payback: 0.98 Years

Optimization Measures

Duct Static Reset

Does the system really require a duct static set point of 1.5" or can it be reset to 0.8"?

Example:

- 700,000 SF Facility
- Duct static set point reset from 1.5" to 1.0" based on ongoing critical zone analysis
- Annual kWh Savings: 153,102 kWh
- Annual Cost Savings: \$11,611
- Measure Cost: \$3,085
- Simple Payback: 0.27 Years

Condenser Water Reset

Most chillers can function with 25 degrees of lift

- Example: 42 degree CHWS temp = 67 degree CWS temp
- Are chillers set to operate at 80 degree CWS Temp?
- Why not reset to 78 or 75 when the OA WB allows?
- Typically 2% efficiency increase for every one degree decrease in CWS temp

- Chiller Plant with Two (2) 500 Ton Chillers
- Reset CWS from 79F to 65F
- Annual kWh Savings: 160,439 kWh
- Annual Cost Savings: \$10,429
- Measure Cost: \$1,300
- Simple Payback: 0.12 Years

Chiller Plant Staging Optimization

Example:

- Chiller Plant with Four (4) 600 Ton Chillers
- Optimized the stage-up and stage-down set-points to of chillers, pumps, and cooling towers.
- Tuned the PID loop on the condenser water bypass valve to provide more stable operation and optimize chiller efficiency.
- Annual kWh Savings: 475,526 kWh
- Annual Cost Savings: \$30,909
- Measure Cost: \$2,000
- Simple Payback: 0.06 Years

Correct Scheduling of Kitchen Make-up Air and Exhaust System

Example:

- Kitchen make-up air unit and exhaust fans were running 24x7.
- Equipment was scheduled from the front end
- Annual kWh Savings: 296,067 kWh
- Annual Therm Savings: 16,321 Therms
- Annual Cost Savings: \$31,998
- Measure Cost: \$0
- Simple Payback: Instant

Night Set-Back On VAV and FPBs Not Active

Example:

- Approx. 1,000,000 SF Facility
- All zones had night setbacks programmed at the front end, however none of the zones were actively controlling to night setbacks.
- Annual kWh Savings: 708,985 kWh
- Annual Cost Savings: \$46,084
- Measure Cost: \$5,563
- Simple Payback: 0.12 Years

Enthalpy Sensor Calibration and Rebalancing of OA Dampers

Example:

- Approx. 500,000 SF Facility
- Existing enthalpy sensors were out of calibration
- OA damper minimum position was bringing in more OA than required
- Enthalpy sensors were replaced and OA damper minimum position was rebalanced.
- Annual kWh Savings: 166,866 kWh
- Annual Cost Savings: \$12,132
- Measure Cost: \$11,950
- Simple Payback: 0.98 Years

Improper VAV Box Airflow

Example:

- Approx. 1,000,000 SF Facility
- Analytics showed that:
- Some boxes had improperly set airflow minimums (too high)
- Some boxes provided too much airflow at maximum
- Some boxes did not show a change of airflow regardless of damper position (command)
- Annual kWh Savings: 96,425 kWh
- Annual Cost Savings: \$7,714
- Measure Cost: In House Corrections

Example Projects

Corrective Measures

Correct Scheduling of Kitchen Make-up Air and Exhaust System

Example:

- Kitchen make-up air unit and exhaust fans were running 24x7.
- Equipment was scheduled from the front end
- Annual kWh Savings: 296,067 kWh
- Annual Therm Savings: 16,321 Therms
- Annual Cost Savings: \$31,998
- Measure Cost: \$0
- Simple Payback: Instant

Night Set-Back On VAV and FPBs Not Active

Example:

- Approx. 1,000,000 SF Facility
- All zones had night setbacks programmed at the front end, however none of the zones were actively controlling to night setbacks.
- Annual kWh Savings: 708,985 kWh
- Annual Cost Savings: \$46,084
- Measure Cost: \$5,563
- Simple Payback: 0.12 Years

Improper VAV Box Airflow

Example:

- Approx. 1,000,000 SF Facility
- Analytics showed that:
 - Some boxes had improperly set airflow minimums (too high)
 - Some boxes provided too much airflow at maximum
 - Some boxes did not show a change of airflow regardless of damper position (command)
- Annual kWh Savings: 96,425 kWh
- Annual Cost Savings: \$7,714
- Measure Cost: In House Corrections

Enthalpy Sensor Calibration and Rebalancing of OA Dampers

Example:

- Approx. 500,000 SF Facility
- Existing enthalpy sensors were out of calibration
- OA damper minimum position was bringing in more OA than required
- Enthalpy sensors were replaced and OA damper minimum position was rebalanced.
- Annual kWh Savings: 166,866 kWh
- Annual Cost Savings: \$12,132
- Measure Cost: \$11,950
- Simple Payback: 0.98 Years

Optimization Measures

Duct Static Reset

Does the system really require a duct static set point of 1.5" or can it be reset to 0.8"?

Example:

- 700,000 SF Facility
- Duct static set point reset from 1.5" to 1.0" based on ongoing critical zone analysis
- Annual kWh Savings: 153,102 kWh
- Annual Cost Savings: \$11,611
- Measure Cost: \$3,085
- Simple Payback: 0.27 Years

Condenser Water Reset

Most chillers can function with 25 degrees of lift

- Example: 42 degree CHWS temp = 67 degree CWS temp
- Are chillers set to operate at 80 degree CWS Temp?
- Why not reset to 78 or 75 when the OA WB allows?
- Typically 2% efficiency increase for every one degree decrease in CWS temp

- Chiller Plant with Two (2) 500 Ton Chillers
- Reset CWS from 79F to 65F
- Annual kWh Savings: 160,439 kWh
- Annual Cost Savings: \$10,429
- Measure Cost: \$1,300
- Simple Payback: 0.12 Years

Chiller Plant Staging Optimization

Example:

- Chiller Plant with Four (4) 600 Ton Chillers
- Optimized the stage-up and stage-down set-points to of chillers, pumps, and cooling towers.
- Tuned the PID loop on the condenser water bypass valve to provide more stable operation and optimize chiller efficiency.
- Annual kWh Savings: 475,526 kWh
- Annual Cost Savings: \$30,909
- Measure Cost: \$2,000
- Simple Payback: 0.06 Years

Duct Static Reset

Does the system really require a duct static set point of 1.5” or can it be reset to 0.8”?

Example:

- 700,000 SF Facility.
- Duct static set point reset from 1.5” to 1.0” based on ongoing critical zone analysis
- Annual kWh Savings: 153,102 kWh
- Annual Cost Savings: \$11,611
- Measure Cost: \$3,085
- Simple Payback: 0.27 Years

Condenser Water Reset

Most chillers can function with 25 degrees of lift

- Example: 42 degree CHWS temp = 67 degree CWS temp
 - Are chillers set to operate at 80 degree CWS Temp?
 - Why not reset to 78 or 75 when the OA WB allows?
 - Typically 2% efficiency increase for every one degree decrease in CWS temp
-
- Chiller Plant with Two (2) 500 Ton Chillers
 - Reset CWS from 75F to 65F
 - Annual kWh Savings: 160,439 kWh
 - Annual Cost Savings: \$10,429
 - Measure Cost: \$1,300
 - Simple Payback: 0.12 Years

Chiller Plant Staging Optimization

Example:

- Chiller Plant with Four (4) 600 Ton Chillers
- Optimized the stage-up and stage down set-points to of chillers, pumps, and cooling towers.
- Tuned the PID loop on the condenser water bypass valve to provide more stable operation and optimize chiller efficiency.
- Annual kWh Savings: 475,528 kWh
- Annual Cost Savings: \$30,909
- Measure Cost: \$2,000
- Simple Payback: 0.06 Years


Monitoring Based Commissioning

Use of real-time data analytics, algorithms, diagnostics, and fault detection, to ensure the facility is operating properly and to continually improve operation 24x7



MBCx

Monitoring based commissioning (MBCx) combines building energy system monitoring with standard retro-commissioning (RCx) practices. MBCx is a measurement-based paradigm that allows improved risk management by identifying problems and opportunities that are missed with periodic commissioning or basic functional testing that does not incorporate energy measurement.



How do you get the data?



How do you access the data?

- Web-Based
- VPN, Remote Desk-Top Connection, Team Viewer
- Mobile App




Other Considerations

- Security
- Liability
- Do you want the analytics platform to make changes?
- Dashboards
- Mobile Apps
- FM / CMMS

Monitoring Based Commissioning and Data Analytics for Energy Efficiency

HEES 2016 Annual Conference
May 6, 2016



MBCx through the Life of your Building

